

LEVEL 1

No.	Area	(sqm)		opening requirement	opening provided	
			sub-total	10%	sqm	(%)
1	Retail 01		324.00			
	Shop	318.43		31.84	38.88	12.21
	Toilet	5.57		0.56	MV	-
2	Retail 02		115.31			
	Shop	111.30		11.11	34.56	31.11
	Toilet	4.21		0.42	MV	-
3	Retail 03		102.97			
	Shop	79.51		7.95	17.28	21.73
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
4	Retail 3A		124.60			
	Shop	101.14		10.11	17.28	17.09
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
5	Retail 05		105.92			
	Shop	89.06		8.91	12.96	14.55
	Toilet	3.30		0.33	MV	-
	Frontage	13.56		-	-	-
6	Retail 06		124.61			
	Shop	101.15		10.12	17.28	17.08
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
7	Retail 07		124.61			
	Shop	101.15		10.12	17.28	17.08
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
8	Retail 08		124.61			
	Shop	101.15		10.12	17.28	17.08
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
9	Retail 09		124.61			
	Shop	101.15		10.12	17.28	17.08
	Toilet	3.30		-	MV	-
	Frontage	20.16		-	-	-
10	Retail 10		113.68			
	Shop	84.23		8.42	21.6	25.64
	Toilet	2.69		0.27	MV	-
	Frontage	26.76		-	-	-
11	Retail 11		117.39			
	Shop	85.78		8.58	21.6	25.18
	Toilet	4.01		0.40	MV	-
	Frontage	27.6		-	-	-
12	Retail 12		124.61			
	Shop	100.44		10.04	17.28	17.20
	Toilet	4.01		0.40	MV	-
	Frontage	20.16		-	-	-
13	Retail 12A		113.89			
	Shop	90.43		9.04	17.28	19.11
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
14	Retail 12B		97.18			
	Shop	73.24		7.32	17.28	23.59
	Toilet	3.30		0.33	MV	-
	Frontage	20.64		-	-	-
15	Retail 15		121.64			
	Shop	97.95		9.80	17.28	17.64
	Toilet	4.01		0.40	MV	-
	Frontage	19.68		-	-	-
16	Retail 16		130.15			
	Shop	105.08		10.51	34.56	32.89
	Toilet	4.01		0.40	MV	-
	Frontage	21.06		-	-	-
17	Retail 17		130.15			
	Shop	105.79		10.58	34.56	32.67
	Toilet	3.30		0.33	MV	-
	Frontage	21.06		-	-	-
18	Retail 18		181.29			
	Shop	144.89		14.49	28.08	19.38
	Toilet	3.30		0.33	MV	-
	Frontage	33.10		-	-	-
19	Retail 19		169.25			
	Shop	137.86		13.79	21.6	15.67
	Toilet	4.01		0.40	MV	-
	Frontage	27.38		-	-	-
20	Retail 20		129.57			
	Shop	104.60		10.46	17.28	16.52
	Toilet	4.01		0.40	MV	-
	Frontage	20.96		-	-	-
21	Retail 21		153.95			
	Shop	117.13		11.71	25.92	22.13
	Toilet	3.30		0.33	MV	-
	Frontage	33.52		-	-	-
22	Retail 22		65.93			
	Shop	45.89		4.59	17.28	37.66
	Frontage	20.04		-	-	-
23	Retail 23		124.60			
	Shop	101.14		10.11	17.28	17.09
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
24	Retail 23A		130.15			
	Shop	104.50		10.45	34.56	33.07
	Toilet	3.30		0.33	MV	-
	Frontage	22.35		-	-	-
25	Retail 25		130.17			
	Shop	105.81		10.58	38.88	36.75
	Toilet	3.30		0.33	MV	-
	Frontage	21.06		-	-	-
26	Retail 26		124.60			
	Shop	101.14		10.11	17.28	17.09
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
27	Retail 27		124.24			
	Shop	100.78		10.08	17.28	17.15
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
28	Retail 28		124.60			
	Shop	101.14		10.11	17.28	17.09
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
29	Retail 29		125.20			
	Shop	101.74		10.17	17.28	16.98
	Toilet	3.30		0.33	MV	-
	Frontage	20.16		-	-	-
30	Retail 30		200.50			
	Shop	197.20		19.72	75.6	38.34
	Toilet	3.30		0.33	MV	-
31	Retail 31		87.02			
			87.02	8.70	17.28	19.86
32	Retail 32		87.44			
			87.44	8.74	17.28	19.76
33	Retail 33		45.97			
			45.97	4.60	8.64	18.79
34	Retail 33A		90.91			
			90.91	9.09	32.4	35.64
35	Retail 35		90.91			
			90.91	9.09	32.4	35.64
36	Retail 36		87.02			
			87.02	8.70	17.28	19.86
37	Retail 37		56.00			
			56.00	5.60	17.28	30.86
38	Retail 38		90.49			
			90.49	9.05	17.28	19.10
39	Retail 39		119.14			
			119.14	11.91	17.28	14.50
40	Retail 40		113.96			
			113.96	11.40	17.28	15.16
41	Retail 41		90.91			
			90.91	9.09	32.4	35.64
42	Retail 42		90.91			
			90.91	9.09	32.4	35.64
43	Retail 43		84.96			
			84.96	8.50	17.28	20.34
44	Retail 43A		38.52			
			38.52	3.85	12.96	33.64
45	Retail 45		55.31			
			55.31	5.53	17.28	31.24
46	Retail 46		87.02			
			87.02	8.70	17.28	19.86
47	Retail 47		82.88			
			82.88	8.29	21.6	26.06
48	Retail 48		83.34			
			83.34	8.33	21.6	25.92
49	Retail 49		87.03			
			87.03	8.70	17.28	19.86
50	Retail 50		87.03			
			87.03	8.70	17.28	19.86
51	Retail 51		87.03			
			87.03	8.70	17.28	19.86
52	Retail 52		87.03			
			87.03	8.70	17.28	19.86
53	Retail 53		87.03			
			87.03	8.70	17.28	19.86
54	LPG gas farm		29.67			
	LPG gas farm 01	13.41		-	-	-
	LPG gas farm 02	16.26		-	-	-
56	Jambor		3.14			
			-	-	-	-
57	Riser		21.63			
	Riser 1	4.54		-	-	-
	Riser 2	5.03		-	-	-
	Riser 3	5.03		-	-	-
	Riser 4	7.03		-	-	-
59	Generator		57.51			
	Generator 1	26.93		-	-	-
	Generator 2	30.58		-	-	-
60	Wet riser pump & tank room		71.76			
61	TNB substation		325.86			
	TNB substation 1	131.93		-	-	-
	TNB substation 2	80.63		-	-	-
	TNB substation 3	113.10		-	-	-
62	Main switch		159.94			
	MSB ROOM 01	63.43		-	-	-
	MSB ROOM 02	37.08		-	-	-
	MSB ROOM 03	59.43		-	-	-
63	Studio mail room		53.31			
	Mail room retail 1	8.00		0.80	MV	-
	Mail room apart. 1	20.19		2.02	MV	-
	Mail room retail 2	7.56		0.76	MV	-
	Mail room apart. 2	17.56		1.76	MV	-
64	Fire WB/SPR/WK		10.58			
	Fire wet riser 1	2.49		-	-	-
	Fire wet riser 2	2.3		-	-	-
	Fire wet riser 3	2.89		-	-	-
	Dry Riser					
	Dry riser 1	0.7		-	-	-
	Dry riser 2	0.88		-	-	-
	Dry riser 3	0.66		-	-	-
	Dry riser 4	0.66		-	-	-
65	Water compart.		35.02			
	Water compart. apart. 1	6.88		-	-	-
	Water compart. retail 1	8.90		-	-	-
	Water compart. apart. 2	13.57		-	-	-
	Water compart. retail 2	5.67		-	-	-
66	Refuse		9.08			
	Refuse 1	4.54		0.45	4.80	105.73
	Refuse 2	4.54		0.45	4.80	105.73
67	MDF room		20.12			
			-	-	-	-
68	Suction tank		229.33			
	Suction tank 1	22.49		-	-	-
	Suction tank (FIRE)2	32.15		-	-	-
	Suction tank 3	174.69		-	-	-
69	Fire sprinkler room		79.56			
	Fire sprinkler studio apart.	47.32		-	-	-
	Fire sprinkler retail	32.34		-	-	-
70	Refuse collection centre		104.81			
			-	-	-	-
71	Fire control room		46.60			
	Room	42.31		4.23	MV	-
	Toilet	4.29		0.43	MV	-
72	Toilet		176.15			
	Toilet 1 (M)	18.86		1.89	MV	-
	Toilet 1 (F)	15.5		1.55	MV	-
	OKU 1	5.43		0.54	MV	-
	Toilet 2 (M)	17.95		1.80	MV	-
	Toilet 2 (F)	19.36		1.94	MV	-
	OKU 2	4.93		0.49	MV	-
	Lactation 1	3.93		0.39	MV	-
	Toilet 3 (M)	19.11		1.91	MV	-
	Toilet 3 (F)	13.4		1.34	MV	-
	OKU 3	7.00		0.70	MV	-
	Lactation 2	4.63		0.46	MV	-
	Toilet 4 (M)	14.6		1.46	MV	-
	Toilet 4 (F)	18.42		1.84	MV	-
	OKU 4	5.73		0.57	MV	-
	Lactation 3	7.3		0.73	MV	-
73	Lift		77.92			
	Lift 1	7.16		-	-	-
	Lift 2,3 & 4	24.08		-	-	-
	Lift 5, 6 & 7	24.08		-	-	-
	Lift 8 & 9	14.31		-	-	-
	Lift 10	8.29		-	-	-
75	Circulation area		2,141.94			
	Area		(sqm)	opening requirement	opening provided	
				requirement 5%	sqm	(%)
76	Stairs		sub-total			
	Stairs 1	17.46		1.75	1.08	6.19
	Stairs 2	16.22		1.62	1.08	6.66
	Stairs 3	18.68		1.87	1.08	5.78
	Stairs 4					