



	Diperlukan	Disediakan
Fasa 1		
a) Kedai		
= 1 petak / 500 kp		
= 317,460.03 kp / 500kp		
= 635 petak	1859	1859
b) Pangsapuri Perkhidmatan		
= 1 unit x 2 petak		
= 612 unit x 2 petak		
= 1224 petak		

VOLUME OF BUILDING IN CUBIC METRE	MINIMUM PROPORTIONS OF PERIMETER OF BUILDING
7000 TO 28000	1/6
28000 TO 58000	1/4
58000 TO 84000	1/2
84000 TO 112000	3/4
112000 AND ABOVE	ISLAND SITE

VOLUME CALCULATION	
Plot 1	374,034.00 m ³
Total Volume of Proposed Development	374,034.00 m ³

Building volume exceeding 112,000.00 CM therefore will be designed with minimum 6m width access road all round as an Island Site.

BUILDING

- Penggunaan sling bantal untuk mendukung kepala kehadkan-kehadkan USBL 1984 Jadwal Kelatan.
- Setiap kasus kesemutan hendaknya dikegung dengan tembak batu-bata setebal 100mm atau jenis tanga terkuat memenuhi kehadkan-kehadkan USBL 1984.
- Adkan pinlu rintangnng au satu km seperitama yang ditadkan di dalam pinlu. Pemangangan hendaknya terputus sendiri dan terputus rapot.
- Adkan dingind pemetakkan (compartment wall) setebal 100mm/200mm batu-bata yang dibina sehingga paras bunding/koral seperitama yang ditadkan di dalam pinlu.
- Dinding bali blik setu yang disiatkan merbahaya hendaknya setebal 100mm, batu-bata dan pinlutu dari jenis kehadkan au satu km dipanggun dengan "core closer".