



Product Service

Attestation of Conformity

No. N8A 16 06 58643 066

Holder of Certificate: Shanghai Sigriner STEP
Electric Co., Ltd.

No. 1560 Siyi Road.
Jiading District
201801 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Product: Converter
Energy Regenerator Device

Model(s): AS.RG4018E, AS.RG4022E, AS.RG4030E

Parameters:

Rated input voltage:	500V-750V d.c.
Rated input current:	31A (AS.RG4018E); 37A (AS.RG4022E); 49A (AS.RG4030E)
Rated input power:	20kW (AS.RG4018E); 24kW (AS.RG4022E); 32kW (AS.RG4030E)
Rated output voltage:	3PH, AC380V~400V
Rated output current:	28A (AS.RG4018E); 34A (AS.RG4022E); 42A (AS.RG4030E)
Rated output power:	18,5kW (AS.RG4018E); 22kW (AS.RG4022E); 30kW (AS.RG4030E)
Rated output frequency:	50/60Hz
Protection class:	I
Degree of protection:	Front: IP20; Rear, side and terminal box: IP00
Rated operation:	Intermittent

Tested according to: EN 62477-1:2012/A11:2014

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704201543204-00

Date, 2016-07-15

(Frank Zhu)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

