

Attestation of Conformity

N8A 16 06 58643 067

Holder of Certificate: Shanghai Sigriner STEP

Electric Co., Ltd.

No. 1560 Siyi Road. Jiading District 201801 Shanghai

PEOPLE'S REPUBLIC OF CHINA

Product: Converter

Energy Regenerator Device

Model(s): AS.RG4011E, AS.RG4015E

Parameters: 500V-750V d.c. Rated input voltage:

> Rated input current: 19A (AS.RG4011E):

27A (AS.RG4015E) Rated input power: 12kW (AS.RG4011E);

17kW (AS.RG4015E)

Rated output voltage: 3PH, AC380V~400V Rated output current:

17A (AS.RG4011E); 24A (AS.RG4015E)

Rated output power: 11kW(AS.RG4011E); 15kW(AS.RG4015E)

50/60Hz

Rated output frequency:

Protection class:

Degree of protection:

Front: IP20:

Rear, side and terminal box: IP00

Rated operation: Intermitten

Tested according to:

EN 62477-1:2012/A11:2014

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

704201543203-00

Frank Hm

2016-07-15

(Frank Zhu)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1